


# SEP2 Implementation & Testing for Dynamic Connections

EECON2024 Nov 2024

Alex Guinman

Jaimee Hosking





## Callide Power Station 1,548 MW




~4,500 PV  
applications/month  
~0.5 GW a year

1 Callide of capacity  
every 3 years




## Rooftop Solar 0.010 MW

# Dynamic Operating Envelopes (DOE)



# AS 5385 or IEEE 2030.5 Smart Energy Profile Application Protocol (SEP2)



# SA HB 218 (CSIP-AUS)



# Internet Outages

Without sensible fallback mechanisms, what might a communication outage look like once most customers are dynamic?

- Customer changes Wi-Fi password
  - 1 customer = 0.01 MW
- Local suburb telco outage
  - 10k customers = 100 MW
- Major Telco outage or DNSP Utility Server outage
  - ~10+ GW of capacity


# Forecasting and Loss of Comms

Import / Export Limits can be scheduled into the future in case of loss of comms.

It is a CSIP requirement that clients store at least 24 scheduled events for each DER that can be actioned in response to a loss of communications.

We aim to send forecasts at:

- 5 min intervals for first hour (12 events)
- 30 min intervals for next 23 hours (46 events)



# Ramping and Randomization

SEP2 provides ability to specify ramp rates per event and for fallback state. It also allows for setting a random delay at the start and end of events.




# Ramping


But beware ... we are talking about limits and not controls.

Ramping does not apply to the actual power output, but the allowed limit.

Anything less than the limit is compliant.




# Communication Protocols




# Laboratory Testing

- AS4777.2:2020 compliance - interoperability of export control & volt-var/volt-watt response
- End-to-end connection of SEP2 Utility Server
- Review of customer & installer experience
- System operation & failure modes




# Test Setup



# Results – Operation

<input checked="" type="checkbox"/>	Interoperability of volt-var, volt-watt & export control.
<input type="checkbox"/>	Reactive Power non-compliance identified, in line with AEMO's DER compliance findings.
<input checked="" type="checkbox"/>	Export control effective while supplying customer's local load requirements.
<input checked="" type="checkbox"/>	System can correctly adhere to a base 1.5kW export limit.
<input checked="" type="checkbox"/>	System can be monitored by customer via the dedicated mobile application.



# Results – Communication Outages

- System dropped to a minimum export limit during internet outages.
  - No locally stored forecasts - export limited when connection to the Cloud Proxy is lost.

Interestingly we found...

- 0 kW export limit implemented at inverter, if gateway device is unreachable.
  - May not meet customers' expectations of a 1.5kW min. as per network agreement.
- System drops instantly to the minimum export limit, rather than ramping down.





# Compliance Test

An export limit compliance test was carried out on Wed 21 August 2024 (14:35 to 14:50). Three individual 5-minute tests were carried out, to understand compliance of different functionality.

- A. Reduced export limit** – The export limit of the DOE Program associated with each NMI was reduced to the fixed export limit of the customer contract.
- B. System-wide program** – All NMIs were enrolled a global system program with higher priority (lower primacy) that was issued with a 1.5 kW export limit.
- C. Fallback limits** – The standard DOE program was cancelled, requiring sites to revert to their fixed export limit.

	2024-08-21	14:30 - 14:35	14:35 - 14:40	14:40 - 14:45	14:45 - 14:50	14:50 - 14:55
DOE Program (Primacy #2)		ExpLimW = 10.0 kW ImpLimW = 15.0 kW	<b>ExpLimW = 1.5 kW</b> ImpLimW = 15.0 kW	ExpLimW = 10.0 kW ImpLimW = 15.0 kW	No dispatch	ExpLimW = 10.0 kW ImpLimW = 15.0 kW
System Program (Primacy #1)				<b>ExpLimW = 1.5 kW</b>		
DefaultControl					ExpLimW = 1.5 kW ImpLimW = 1.5 kW	
Fixed Limits					ExpLimW = 1.5 kW ImpLimW = 1.5 kW	
Implied Mode Defaults					GenLimW = $\infty$ kW LoadLimW = $\infty$ kW Connect = True Energize = True	
Site Behaviour		ExpLimW = 10.0 kW ImpLimW = 15.0 kW	ExpLimW = 1.5 kW ImpLimW = 15.0 kW	ExpLimW = 1.5 kW ImpLimW = 4.0 kW	ExpLimW = 1.5 kW ImpLimW = 4.0 kW	ExpLimW = 10.0 kW ImpLimW = 15.0 kW
Notes	Normal		Exp 1.5 kW A - Reduced DOE	Exp 1.5 kW B - System Program	Exp 1.5 kW C - Default Control	Normal


# Customer Examples



Unrelated  
Cloud Proxy  
Service Outage



# Customer Examples



Sites not communicating with server  
... so should have been max 1.5 kW Export



# Compliance Rates with Export Limit

What percentage of sampled customers exceeded the expected export limit at the time of the test?

	<input checked="" type="checkbox"/> Exporting at or below limit	<input type="checkbox"/> Exporting above limit
Fixed – Full Export	98%	2%
Fixed – Partial Export	55%	45%
Fixed – Non-Export	19%	81%
Dynamic – Unregistered	24%	76%
Dynamic – Communicating	57%	43%

Note: for fixed connections, the max 5 min export for the whole day was used to determine compliance.

# Next Steps

- CSIP-AUS Test Procedures updated with additional tests
- Standards Australia “Behind-the-Meter Interoperability for Inverter Energy Systems” proposal
- Requirement for local storage of forecasts in future CSIP-AUS revision?
- Future mechanism for customers to better diagnose problems
- New Connection Process and Compliance team at Energy Queensland

